

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-01-08-05

Product: Quick-Step Parquet, 14 mm + 12.5 mm, Lacquered/Oiled, Fumed / Not Fumed
Hevea core & HDF core

Producer: Unilin Flooring BV, Ooigemstraat 3, 8710 Wielsbeke, Belgium

Order: Testing and classification of selected properties
according to EN 14342:2013 (CE-labelling)

Test reports: 2717589


Test results:

Property	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1:2010 and EN ISO 11925-2:2011; Classification according to EN 13501-1:2010	Reaction to fire class C _{fl} - s1
Formaldehyde emission according to EN 717-1:2005	class E1
Content of PCP according to CEN/TR 14823:2004	PCP ≤ 5 x 10 ⁻⁶ n
Anti-skid properties according to CEN/TS 15676:2008	USRV 37 / USRV 57
Thermal conductivity according to EN 12664:2001	0.14 (m ² K)/W

Dresden, 08/01/2019



Head of laboratory

Engineer in charge